

LEGEND + ABBREVIATIONS

- EXISTING TO REMAIN UON

(ER) EXISTING TO BE REMOVED AND REPLACED WITH NEW AS SHOWN

NEW AS SHOWN, SEE APPROPRIATE SYMBOL BELOW

(R),-- EXISTING TO BE RELOCATED AS SHOWN, SEE PLAN

⇌ DUPLEX RECEPTACLE

2-DUPLEX RECEPTACLE

WIRE/RACEWAY: "HOMERUN", MIN SIZE #12 SEPARATE NEUTRAL FOR EACH CIRCUIT COMMON PARITY GROUND IN 3/4" C UON

AFF ABOVE FINISHED FLOOR

UON UNLESS OTHERWISE NOTED

① SHEETNOTE IDENTIFICATION TAG

8 FIRE ALARM BELL

 \bigcirc v FIRE ALARM BELL WITH STROBE LIGHT

FIRE ALARM STROBE LIGHT



SHEET NOTES:

1 FIELD CURRENT MEASUREMENT IN THE EXISTING BELL CKT (FAP-01-77, MOD 7 / AE-30 OR MOD 4, CP-30) IS 1.44 AMP.

REPLACE (2) - EXISTING FA BELL & INSTALL (1)-MEW FA BELL WITH "AMSECO" MSB SERIES TYPE MOTOR DRIVEN FIRE BELL, 24/DC, LOW CURRENT 0.305 AMP.

NEW FA BELL CKT CURRENT WILL BE {1.44 - (.07 + .07)} = {1.30 + 3 x (.030)} = 1.39 AMP.

REFER TO FIRE ALARM SYSTEM DWG. 4877E054E TO BE ISSUED LATER UNDER FIRE ALARM REHAB PROJECTS.

GENERAL NOTES:

- 1 ALL ELECTRICAL EQUIPMENT, DEVICES & INSTALLATION SHALL COMPLY WITH LBNL ELECTRICAL STANDARDS/SPECIFICATIONS & LATEST EDITION OF NEC.
- 2 PRIOR TO CONSTRUCTION FIELD VERIFY & CHECK EXISTING CONDITIONS, ELEVATIONS, DIMENSIONS AND INFORM INSIGHT, CONSTRUCTION SUPERINTENDANT OF CONFLICTS, INTERFERENCES & UNEXPECTED CONDITIONS.
 3 CONDUIT & WIREWAY ROUTING ARE DIAGRAMATIC, MINIMUM SIZE OF CONDUIT IS 3/4" & #IZANG FOR WIRE. SUPPORT CONDUITS & WIREWAY AT LEAST EVERY 10 FEET OR AS REQUIRED.
- 4 FIELD TO VERIFY & CHECK EQUIPMENT RATING, INTERCONNECTIONS, PRIOR TO TIE—DOWNS.
- 5 TAG & LABEL ALL ELECTRICAL EQPT & DEVICES WITH CIRCUIT NOs. AND/OR EQUIPMENT NOs.
- 6 FIELD TO SUBMIT MARKED-UP PRINTS AFTER THE INSTALLATIONS COMPLETE FOR "AS-BUILT".
- 7 SEAL ALL CONDUIT PENETRATIONS WITH LBNL APPROVED FIRE SEALANT.

